

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. 1029

Date : 18/3/24

It is certified that an inspection team headed by Md. Shami Akhtar
Executive Engineer (Name of Officers
with designation) from P. H. E. D. Aurangabad (Name of
Department/Office) inspected the Bal Bharati Public
School NTPC Navinagar Aurangabad (Name & Address of
the School) on 14.03.24 and found that the Bal Bharati
Public School (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of One year.

All tested parameter
are in permissible limit

Shailendra
16.03.24

रमायनज

लोक स्वास्थ्य प्रमंडल
औरंगाबाद (बिहार)

Signature with Seal :

Name :

Designation :

Executive Engineer
P. H. DIVISION

Aurangabad
Shailendra
16.3.24

To

Bal Bharati Public school

NTPC Navinagar

Aurangabad 824303

(Name & Address of the Institution)

Government of Bihar
District Level Water Testing Laboratory
 P.H. Division, Aurangabad
 Water Quality Testing Report

Sample sent to Lab by-Chemist
 Sample Submitted in Lab on date:-29.02.2024

District Name:- Aurangabad

S. N.	Block	Panchayat	Habitatoin/Muhalla	Location	Type of source	p.H	Tur	EC	Tds	TH	Ca	MG	ALk	Cl	Fe	No3	So4	F	T. Coli.	All tested parameter are in accepted Limit
1	Navinagar	Akorha	Akorha	Bal bharti pblice school NTPC Navinagar	Boring	7.91	0.99	291	168	104	41.6	0	116	65.96	NT	BDL	BDL	0.52	N	
Acceptable Limit (IS 10500:2012)						6.50	1	-	500mg/l	200mg/l	75 mg/l	30 mg/l	200 mg/l	250 mg/l	0.3 mg/l	45 mg/l	200 mg/l	1.0 mg/l	<1.1	
Maximum Permissible Limit in absence of alternate source						8.50	5 NTU	-	2000 mg/l	600 mg/l	200 mg/l	100 mg/l	600 mg/l	1000 mg/l	1 mg/l	NR	400 mg/l	1.5 mg/l	NR	

Copy to :-Bal Bharati Publice School NTPC Navinagar Aurangabad, Ref. Letter No.-090 Dated-27.02.2024 Your DD No.981917 dated 26.02.24 Amount Rs.600/=

Shailam
 16.03.24

Chemist
रसायनज्ञ
 लोक प्रमुख प्रमंडल
 औरंगाबाद (बि.प्र.)

Shailam
 16/03/24
 Assistant Engineer
 P.H. Division Aurangabad
 लोक सेवा अवर प्रमंडल
 औरंगाबाद

Shailam
 16/03/24
 Executive Engineer
 P.H. Division Aurangabad
 लोक सेवा अवर प्रमंडल
 औरंगाबाद