



जिला जल जाँच प्रयोगशाला
लोक स्वास्थ्य प्रमंडल, औरंगाबाद
निर्गत सं०...५३.....
तिथि....13/3/2025

PERFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by **Md Shami Akhatar Executive Engineer.**
(Name of Officer with designation) from...**PHED PH Division Aurangabad** (Name of
Department/Office) inspected the **Bal Bharati Public School NTPC Nabinagar , Aurangabad.**
(Name and Address of the School) on **07.03.25** (Date of Inspection) and found that the
Bal Bharati Public School NTPC Nabinagar , Aurangabad. (Name of School) has safe drinking
water facilities for the student and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per norms
prescribed by the Central/State/U.T. Govt.

The above is valid for a period of **Six months.**

*All Tested parameter are
in permissible Range.*

Shaitano
13.03.25

Chemist
P.H. Div. Aurangabad

Chemist
P.H Division
Aurangabad

Shaitano
13/03/25
Assistant Engineer
P.H. Div. Aurangabad
Technical Manager
Com
Assistant Engineer
P.H. Division, Aurangabad

Signature with Seal:
Name
Designation
Name & Address of the office/ Department.....

Quality Manager
Cum
Executive Engineer
P.H Division, Aurangabad

To

Shaitano
Bal Bharati P/s 'NTPC
Nabinagar ,Aurangabad



Government of Bihar
District Level Water Testing Laboratory
P.H. Division, Aurangabad

जिला जल जाँच प्रयोगशाला
लोक सदा प्रमदल, औरंगाबाद
निर्गत सं०.....५२.....
दिथि.....१३/३/२०२५

Sample sent to Lab by :- Self

District Name:- Aurangabad

Sample Submitted in Lab on date :- 07.03.25

S. N.	Block	Panchayat	Location of source	Chemical Parameters												
				p.H	Tur	EC	TDS	TH	Ca	Mg	Alk	Cl	Fe	SO ₄	F	T. Coli.
1	Nabanagar	Akorha	Bal Bharti Public School NTPC Nabinagar	7.29	0.28	284	184.6	104	49.60	10.2	106	50.98	0.31	32	0.81	-VE
Acceptable Limit (IS 10500:2012)				6.50	1	-	500 mg/l	200 mg/l	75 mg/l	30 mg/l	200 mg/l	250 mg/l	1 mg/l	200 mg/l	1.0 mg/l	<1.1
Maximum Permissible Limit in absence of alternate source				8.50	5 NTU	-	2000 mg/l	600 mg/l	200 mg/l	100 mg/l	600 mg/l	1000 mg/l	NR	400 mg/l	1.5 mg/l	NR
Remarks:- All Tested Parameters are in permissible range.																

Bal Bharti Public School के द्वारा कार्यपालक अभियंता को जल नमूना जाँच हेतु 600 रुपये का Demand Draft दिनांक

05.

03.25 संख्या 981944 प्राप्त हुआ है।

Shalini
Chemist
P.H. Division Aurangabad
Aurangabad

Assistant Engineer
P.H. Division Aurangabad
Com

Executive Engineer
P.H. Division Aurangabad
Quantity Manager
Com

Executive Engineer
P.H. Division, Aurangabad